

## GENERAL NOTES:

A. FURNISH AND INSTALL PULLBOXES FOR ALL SITE CONDUITS AS

B. FURNISH AND INSTALL PULL CORDS IN EACH NEW CONDUIT.C. COORDINATE AND COMPLY WITH ALL UTILITY STANDARDS AND REQUIREMENTS.

D. ALL SITE ELECTRICAL CONDUCTORS BELOW GRADE SHALL BE ROUTED IN SCHEDULE 40 PVC CONDUIT, 1" MINIMUM. INSTALL AT DEPTH REQUIRED BY NEC FOR CONDITIONS OF INSTALLATION.
E. ALL EXTERIOR ELECTRICAL BOXES, FITTINGS, AND CABINETS SHALL BE OF STEEL CONSTRUCTION, GALVANIZED OR POWER COATED, NEMA 3R TYPE, UNLESS OTHERWISE NOTED.

## # SHEET NOTES:

1. ROUTE THROUGH LIGHTING CONTROL PANEL 'LCP' RELAY SWITCH.

2. FURNISH AND INSTALL A WEATHERPROOF GFCI RECEPTACLE WITH A METAL IN-USE LOCKABLE COVER, TAYMAC OR EQUAL. MOUNT ON SECURE WEATHERPROOF 4" X 4" [102MM X 102MM] METALPOST 18" [457MM] ABOVE FINISHED GRADE. COORDINATE FINAL LOCATION AND MOUNTING REQUIREMENTS WITH OWNERS AGENT. CIRCUIT AS INDICATED.

3. INTERIOR CIRCUIT BRANCH PANEL AND LIGHTING CONTROL PANEL. SEE SHEET E2.1 AND E3.1.

4. IRRIGATION CONTROLLER. FURNISH AND INSTALL POWER CONNECTION FOR CONTROLLER AS INDICATED. COORDINATE LOCATION AND ALL ELECTRICAL REQUIREMENTS WITH IRRIGATION CONTRACTOR PRIOR TO ROUGH—IN.

5. REMOVE ALL ELECTRICAL FROM THE EXTERIOR OF BUILDING 33, INCLUDING

BUT NOT LIMITED TO, HVAC UNIT FEEDERS, CONDUITS RUNNING ON SURFACE OF THE BUILDING, ALL PENETRATIONS OF ELECTRICAL THROUGH EXTERIOR WALLS. COORDINATE THE REPAIR OF PENETRATIONS THROUGH WALL WITH THE GENERAL CONTRACTOR AND THE ARCHITECT.

03/04/11

PROJECT NO.
531-10-114

DRAWING NO.

